

Electrical Conditions

1. All equipment regardless of source of power must comply with the National Electrical Code, and all Federal, State, and Local Safety Codes.
2. Use of open clip sockets, latex or lamp cord wire, unapproved duplex or triplex attachment plugs in exhibits is prohibited.
3. Permanent building electrical outlets are not a part of booth space and are not to be used by exhibitors.
4. Under NO circumstances shall anyone other than an OCCC electrician make electrical connections to house equipment.
5. Special equipment requiring company engineers or technicians for assembly, servicing, preparatory work, and operation may be executed without a house electrician; however, all service connections and overload protection to such equipment must be made by a house electrician only.
6. All equipment must be properly tagged or marked with complete information as to the type and/or amount of current, voltage, phase, frequency, horsepower, etc. required.
7. All material and equipment furnished by the OCCC for this service order shall remain the property of the OCCC and shall be removed ONLY by the OCCC at the close of the show.
8. Unless otherwise directed, OCCC electricians are authorized to cut floor coverings to permit installation of service.
9. All 120V cords must be of the 3 wire, grounded type. All exposed non-current carrying metal parts of fixed equipment, which are liable to be energized, shall be grounded.
10. The OCCC reserves the right to refuse connection to any exhibitor whose equipment is deemed unsafe by the OCCC.
11. Orders received during the incentive period will receive priority over base or on-site orders.
12. The exhibitor releases, waives and holds harmless the OCCC, its officers, employees and agents for any liability, claims, and damages arising out of any of the services or equipment provided herein. The exhibitor shall indemnify the OCCC for any bodily injury or property damage resulting from any negligent act or omission of the exhibitor, its officer, employees or agents.
13. Claims will NOT be considered unless filed by Exhibitor before the close of show at the Service Desk.
14. Obstructions blocking utility floor boxes are subject to relocation as necessary.
15. The OCCC will charge time and materials for exhibitor or appointed contractor installed cords, which require troubleshooting and/or redistribution.
16. All electrical services are to be billed to the next greatest wattage (i.e. 15amp 208v single phase = 20amp 208v single phase).
17. The OCCC does not provide distribution panels. If an exhibitor orders "bulk power", the OCCC will not provide distribution panels to the exhibitor; they must provide their own.

Plumbing, Compressed Air & Gas Conditions

1. Plumbing services are only available from the floor.
2. Compressed air pressure may vary. No guarantee can be made of minimum and maximum pressure. If pressure is critical, please contact Exhibitor Services at (407) 685-9824.
3. Booth anchoring/drilling must have prior approval by Show Management and the OCCC and must be performed by the OCCC.
4. The OCCC will not branch/split gas from one location to another to achieve multiple locations. The OCCC is not responsible for gas distribution installed by others.
5. All gas will be removed or shut off one hour after the close of each day. LP gas prices include hook-up and dismantle of tank each day.
6. Please provide an attached drawing indicating location of your connection(s). If a drawing is not provided, the OCCC will install the service in the most convenient location and charges will apply for relocation.
7. Labor charges will apply for service calls.
8. All equipment must comply with the Southern Building Code, all Federal, State, and local safety codes.
9. Claims will NOT be considered unless filed by Exhibitor before the close of show at the OCCC Exhibitor Services desk.
10. All material and equipment furnished by the OCCC shall remain the property of the OCCC and shall be removed ONLY by the OCCC at the close of show.
11. Unless otherwise directed, OCCC personnel are authorized to cut floor coverings to permit installation of service.
12. The exhibitor must notify the OCCC Exhibitor Services desk for installation if no detailed diagram has been submitted indicating the location of the ordered services.