

Fire and Safety Regulations

This Facility is located in a School Zone as defined by the Gun Free School Zone Act 18 U.S.C. adopted November 29, 1990 (the Act). All persons are prohibited from possessing firearms on the premises unless such possession is authorized by exceptions listed in the Act **or as authorized by the Commonwealth of Kentucky**. Licensor also reserves the right to restrict or prohibit possession of other weapons such as knives and other dangerous weapons.

All exit doors must be fully operable and unobstructed during all times of occupancy. Exit signs shall remain illuminated and fully visible.

Use of the Facilities for a trade show or public exhibit purposes requires a detailed floor plan depicting the intended use of the area. Floor plan will be submitted to the CORPORATION for review and approval by the Center and local fire marshal where appropriate. Displays located in corridors shall be located to one side leaving an eight foot wide clear walking path. Approval of plans shall be obtained prior to sale or allocation of space to potential exhibitors.

Rigging plans must be submitted for approval for events that require equipment in excess of 100 lbs. to be suspended from the ceiling. Rigging of AV equipment and/or production equipment must be performed by CORPORATION staff or its authorized representatives as an Ancillary Service.

Any use of open flames or smoke generating substances or equipment must receive prior approval.

All decorations and construction materials must be non-combustible or flame retardant (documentation is required). This includes, but is not limited to, organic decorations such as mulch, hay bales, etc.

Electrical devices must be installed, operated, and maintained in accordance with manufacturers' intended use and applicable codes. In any case, electrical devices that create a hazard to life or property are not permitted.

Internal combustion equipment and motor vehicles may be displayed under the following conditions:

- Fuel supply limited to that necessary for installation and removal of equipment.
- Fuel tanks must have pressure released by removing fuel cap after vehicle has reached display position, and then the fuel cap must be locked or sealed.
- Electrical power supply must be disconnected.
- Keys must be removed from ignition and will be retained at CORPORATION Security Headquarters.
- Motor vehicles are prohibited in carpeted areas, unless under the direction of CORPORATION management, to take precautions for protection of CORPORATION property.
- Any use of motorized vehicle in the Facilities is subject to prior approval of the CORPORATION. Use of motorized vehicles during public occupancy of Facility is prohibited.

A maximum of two 20' x 20' tents are allowed per 15,000 square feet of space rented with the following conditions:

- Tents must be non-combustible and flame-proof.
- Tents must be open on all four sides.
- If more than one tent, tents must be spaced at least 20 feet apart.
- No open flames permitted in tents.
- Each tent must be equipped with Type ABC fire extinguisher.
- Exhibitor personnel must occupy tent during show hours.
- Electrical service must be turned off at the conclusion of each show day.

The use, display, or storage of flammable liquids, including LP gas, is prohibited except as authorized by local and state fire regulations. Complying vendors using propane for the purpose of authorized food preparation are subject to the following limitations:

- Compressed gas cylinders must be firmly secured in an upright position.
- Propane storage tanks may be no larger than 5 pounds per booth.
- Booths using propane shall be located no closer than 100 feet apart.
- Additional propane tanks must be stored outside of the building.
- Food preparation is not permitted in carpeted areas.