

ELECTRIC SERVICE CHECKLIST

ELECTRICAL SERVICE IS NOT INCLUDED WITH THE RENTAL OF YOUR BOOTH SPACE. VIOLATORS WILL HAVE THEIR EQUIPMENT DISCONNECTED, AND NOTICE WILL BE SENT TO THE SHOW MANAGER.

- Exhibitors are **NOT PERMITTED** to run cords under carpet.
- Exhibitors are permitted to run cords over the carpet (in booths smaller than 600 square feet) along the drape line or behind a display.
- All exhibitor extension cords must be grounded 3-wire 12-gauge UL listed approved cords.
- Absolutely **NO** household un-grounded cords are permitted.
- Exhibits found to be non-compliant will receive notification and are subject to power interruption until corrected. If not corrected, notification will be sent to the Show Manager.
- Electrical service will be turned off one hour after the close of show and restored one hour prior to opening of show each day. 24 hour service is available upon request for perishables, refrigeration, electronics, pumps, etc. at an additional cost.
- All equipment provided by the exhibitor shall be UL listed and approved. Equipment must be in compliance with the National Electrical Code, Philadelphia Building Codes, Fire Marshall and PCCA/SMG safety standards.
- All electrical equipment and installations are subject to inspection. Any equipment found presenting a hazard will be subject to removal.
- Electrical Distribution panels in the back of booths **MUST** remain accessible at all times. Exhibitors are **PROHIBITED** from accessing panels and PCCA electrical connections.
- All hard wiring and/or splicing of lights and electrical equipment requires an Electrical Labor Order and installation by PCCA/SMG electrician.