

Electrical Service Checklist

- ✓ Electrical service is not included with the rental of your booth space or meeting room.
- ✓ Each electrical drop within the booth must be a minimum of 500 watts. This is for the protection of the equipment getting plugged in, the safety of the people in the booth (exhibitors and attendees), and to prevent over-current interruption during the show.
- ✓ Electrical service will be turned off one hour after the close of show and restored one hour prior to show opening each day. *24HR service is available upon request for perishables, refrigeration, electronics, pumps, etc. at an additional cost.*
- ✓ Exhibitors are **NOT PERMITTED** to run cords under carpet.
- ✓ Exhibitors are permitted to run cords along the drape line **ONLY**.
- ✓ All exhibitor extension cords must be grounded 3-wire 12-gauge UL listed approved cords. (household un-grounded cords are NOT permitted)
- ✓ All equipment provided by the exhibitor shall be UL listed and approved. Equipment must be compliant with the National Electrical Code, Philadelphia Building Codes, Fire Marshal, and PCCA/ASM Global safety standards.
- ✓ Exhibits found to be non-compliant will receive notification and be expected to correct the infraction. If not corrected, additional charges may be incurred.
- ✓ In all booths where an Exhibitor Appointed Contractor (EAC) or decorator is utilized, ASM Global Electricians must install all light fixtures, lit signage, hardwiring, and all other work deemed as electrical jurisdiction.
- ✓ Vehicle batteries shall be disconnected and reconnected by ASM Global Electricians per the Philadelphia Fire Marshal.
- ✓ All electrical equipment and installations are subject to inspection. Any installed equipment found presenting a hazard will be subject to removal or the exhibitor will be responsible for any charges incurred due to corrections.
- ✓ Electrical Distribution panels in the back of booths MUST remain accessible at all times. Exhibitors are PROHIBITED from accessing panels and PCCA electrical connections.
- ✓ Labor calls for PCCA/ASM Global electricians must be selected as “Under Supervision” or “Without Supervision” and noted as such on the Electrical Labor Order form.
“Will Calls” are not acceptable.
- ✓ It is recommended that you supply the Utilities Department with a rendering and scaled floor plan noting power drop locations in your booth and/or meeting room.
- ✓ All on-site orders for electric service and electric labor will be billed at Standard/Show Site Rates and could lead to delays in your booth build.
- ✓ Separately derived electrical systems are NOT PERMITTED to be used in the building.